



ITC Midwest Generator Interconnection Policy

- In 2013 FERC ordered ITC Midwest to revise its cost allocation protocols for generation interconnection to return to the default provisions of Attachment FF of the MISO Tariff in Dockets EL12-104 and ER13-2156.
- The default provisions are summarized as the following:
 - For network interconnection upgrades below 345kV, the generator is responsible for 100% of the cost, and
 - For network interconnection upgrades at or above 345kV, the generator is responsible for 90% of the cost and will be reimbursed 10% of the cost
- Any radial facilities needed to connect the generation to the transmission system remain the cost responsibility of the generator.
- Please refer to the MISO Tariff Attachment FF for the current specific provisions.